

DEPARTMENT OF TRADE AND COMMERCE

Electricity and Gas Inspection Services

Ottawa, December 8th, 1933.

District Inspectors of Electricity & Gas:-

Dear Sirs,- I beg to advise you that the type I.P.16 Prepayment Watthour meter, manufactured by the Canadian General Electric Company, Toronto, Canada, has been approved by the National Research Council and may be admitted to verification in Canada, provided that, the maker's serial number shall be indelibly marked on the body of the meter as well as on the name plate, which is attached to the removable cover.

This meter is composed of the Canadian General Electric Company's type I.16 watthour meter and a prepayment attachment. It will be made in the following capacities:-


Volts - 115 - 2 wire.

Amperes - 10 and 15.

Frequency - 25 and 60 cycles per second.

The inspection fee for this meter will be \$1.20, namely, 60¢ for the watthour meter element and 60¢ for the prepayment attachment.

Yours truly,

  
Director.

JLS/RS.