DEPARTMENT OF TRADE AND COMMERCE

ELECTRICITY AND GAS INSPECTION SERVICES

Ottawa, April 10th, 1934.

District Inspectors of Electricity & Gas:

Dear Sirs,- Re-Landis & Gyr, types DF.4 and
DF.4k watthour meters

I beg to advise you that the following types of meters, manufactured by Landis & Gyr, Inc., Zug, Switzerland, and sold in Canada by Landis & Gyr, Inc., 104 Fifth Avenue, New York City, have been approved by the National Research Council for use in Canada, provided the voltage of the meters be marked on the name plate in accordance with the National Research Council specifications and Canada appractise, that is, "115/230 volts" instead of "2x115 volts":

DF4 - 5/10/15/25 amperes, 115/230 volts, single phase, 3 wire, 60 cycle.

DF4k- 5/10/15/25 amperes, 115/230 volts, single phase, 3 wire, 60 cycle prepayment.

The type DF.4 meter is the three wire construction of the type CF.4 single phase, 2 wire watthour meter approved by N.R.C. Circular #9, and the type DF.4k prepayment meter is the 3 wire construction of the type CF.4k single phase, 2 wire meter approved by N.R.C. Circular #44.

Yours truly,