

N.R.C. 46
Electricity

DEPARTMENT OF TRADE AND COMMERCE
ELECTRICITY AND GAS INSPECTION SERVICES

OTTAWA, April 10th, 1934.

District Inspectors of Electricity & Gas:

Re-Approval of type WD.3 Lincoln Demand Meter


Dear Sirs;-

I beg to advise you that the type WD.3 Lincoln Demand Wattmeter, manufactured by the Sangamo Company, Limited, Toronto, Canada, has been approved by the National Research Council and may be admitted to verification in Canada.

The type WD.3 meter has the same electrical characteristics as the WD.2 with the addition of a temperature compensating device, which was recently approved as a separate item by the National Research Council. There is also a change in the base and cover of the type WD.3 in that it is bottom connected instead of side connected and the element has been reversed so that the pointers now point downward instead of upward.

A diagram showing the internal and external connections of this meter is enclosed for your information.

Yours truly,


Director.

15
PE.