

N.R.C. 48
Electricity

DEPARTMENT OF TRADE AND COMMERCE
ELECTRICITY AND GAS INSPECTION SERVICES

Ottawa, May 25, 1934.

District Inspector of Electricity & Gas:-

Dear Sirs:-


Re-Approval of type WD.3
3 element demand watt-
meter for use on 3 phase,
4 wire circuits.

I beg to advise you that the Lincoln type WD.3, 3 element demand wattmeter for use on 3 phase, 4 wire circuits, manufactured by the Sangamo Company Limited, Toronto, Canada, has been approved by the National Research Council for use in Canada in the following capacities:

Amperes - 5, 10, 15, 25.

Volts - 115, 230, 460, 575.

Yours truly,


Director.