

N.R.C.63
Electricity

DEPARTMENT OF TRADE AND COMMERCE
ELECTRICITY AND GAS INSPECTION SERVICES

Ottawa, January 4th, 1935.


District Inspectors of Electricity & Gas:-

Dear Sirs,

One of our District Inspectors has reported that the sealing device on the Westinghouse type CS wattour meter is not sufficiently effective to prevent access to the meter.

We have examined this meter in the laboratory and find that his contention is correct and, therefore, would ask you to not seal this type of meter until you hear further from this office.

Yours truly,


Director.