

N.R.C. 67
Electricity

DEPARTMENT OF TRADE AND COMMERCE
ELECTRICITY AND GAS INSPECTION SERVICES

OTTAWA, January 26th, 1935.


District Inspectors of Electricity & Gas:

Dear Sirs,-
Re-approval new type of cover for
Sungamo type S.3 single phase
watthour meter

The Sungamo Company of Toronto have developed a new type of glass cover for their type S.3 single phase watthour meter. It is of the studless type and is held in place on the meter by means of a ring and bale, the bale locking into two special rivets. The meter is held in place by two screws located just above the terminal box of the meter and the sealing wire is passed through holes drilled in these screws before entering the sealing cup.

I beg to advise you that this new type of cover has been approved by the National Research Council and type S.3 meters fitted with this cover may be tested and sealed.

Yours truly,


Director.

JLS/RS.