

N.R.C.69
ELECTRICITY

DEPARTMENT OF TRADE AND COMMERCE
ELECTRICITY AND GAS INSPECTION SERVICES

OTTAWA, April 30th, 1935.

District Inspectors of Electricity & Gas:

Re- Approval of Canadian General Electric
type LFM-1 Current Transformer

Dear Sirs,-

I beg to advise you that the type LFM-1 current transformer, manufactured by the Canadian General Electric Company, Toronto, Canada, has been approved by the National Research Council for use with their three wire meters in both 25 and 60 cycle ratings, single phase, above 50 amperes with a burden of one watt-hour meter.

Yours truly,


Director.