

N.R.C.71  
Electricity

DEPARTMENT OF TRADE AND COMMERCE  
ELECTRICITY AND GAS INSPECTION SERVICES

OTTAWA, June 20th, 1935.


District Inspectors of Electricity and Gas:

Re- Approval of New type Scale for use on  
all Lincoln Meters

Dear Sirs:-

I beg to advise you that the Sangamo Company Limited, Toronto, Canada, have submitted to the Laboratory for approval a new type of construction for the scale used on Lincoln meters. This construction consists of raising the scale itself above the surface of the meter dial thus allowing the top of the maximum pointer to be brought considerably closer to the scale and reducing the error due to parallax in readings. This new type of construction of the scale has been approved by the National Research Council for use on all types of Lincoln demand meters.

Yours truly,

  
Director.