

M.R.C. 83.
Electricity

DEPARTMENT OF TRADE AND COMMERCE
ELECTRICITY AND GAS INSPECTION SERVICES

OTTAWA, January 9, 1936.


District Inspectors of Electricity & Gas:

Dear Sirs:

I beg to advise you that the Sangamo Type HFA Watthour Meter, manufactured by the Sangamo Electric Company, Springfield, Ill., U.S.A., and supplied in Canada by the Sangamo Company Limited, Toronto, Canada, is approved by the National Research Council for use in Canada in the following capacities:

Amperes - 5, 10, 15, 25, 50
Voltages - 115, 230, 460, 575
Wire - 2 and 3 wire construction
Frequency - 25 and 60 cycles.

Yours truly,



Director.