

N.R.C. 84.
Electricity

DEPARTMENT OF TRADE AND COMMERCE
ELECTRICITY AND GAS INSPECTION SERVICES

OTTAWA, January 9, 1936.

District Inspectors of Electricity & Gas:

Dear Sirs:


I beg to advise you that the Type C-2 Polyphase Watthour Meter, manufactured by the Canadian Westinghouse Company Limited, Hamilton, Ontario, is approved by the National Research Council for use in Canada in the following capacities:

Amperes - 2.5, 5, 10, ¹⁵ 25, 50 and 75
Voltages - 115, 230, 460, 575 or 120, 240,
480, 600

Frequency - 60 cycles

Circuits - Two-phase, three or four-wire service; three-phase, three-wire service; or in metering a service consisting of two phase wires and the neutral of a three-phase, four-wire AC network.

Yours truly,



Director.