

N.R.C. 85
Electricity

DEPARTMENT OF TRADE AND COMMERCE
ELECTRICITY AND GAS INSPECTION SERVICES

OTTAWA, February 25, 1936.

To District Inspectors of
Electricity and Gas.

Re - Approval of Canadian General Electric
Type I-20-A Watthour Meter.


Dear Sirs:

I beg to advise you that the Type I-20-A
Watthour Meter, manufactured by the Canadian General
Electric Company, Toronto, Canada, has been approved
by the National Research Council for use in Canada
in the following capacities:

Amperes: 5, 10, 15, 25, 50.
Voltages: 115, 230, 460, 575.
Wire: Single phase 2 and 3 wire.
Frequency: 25 and 60 cycles.

It is particularly pointed out that this
approval applies only to the watthour meter itself,
and does not apply to any mounting which might accom-
pany the meter.

Yours truly,


Director.