

DEPARTMENT OF TRADE AND COMMERCE
ELECTRICITY AND GAS INSPECTION SERVICES

OTTAWA, March 18, 1937.

TO DISTRICT INSPECTORS OF
ELECTRICITY AND GAS


Dear Sirs: RE: Approval of Type D-14, Polyphase
Watt-hour meter, for use on 3-phase
4-wire Circuits.

This is to advise you that the type D-14 polyphase watt-hour meter, 3-phase, 4-wire, manufactured by the Canadian General Electric Company, Toronto, Ontario, has been approved by the National Research Council for use in Canada in the following capacities:

Amperes: 5/10/15/25/50;
Voltages: 115/230/460/575;
Frequency: 25 and 60 cycle;
Circuit: 3-phase 4-wire.

This Circular is supplementary to Circular #188, dated the 27th of March, 1929, which Circular did not approve of the type D-14 meter for use on 3-phase, 4-wire circuits.

Yours truly,



Director.

JLS/nec