

N.R.C. 100
Electricity

DEPARTMENT OF TRADE AND COMMERCE
ELECTRICITY AND GAS INSPECTION SERVICES

OTTAWA, Sept. 14, 1937.

TO DISTRICT INSPECTORS OF
ELECTRICITY AND GAS


Re: type approval Sangamo types "GF"
and "GK" potential transformers.

Dear Sir:

This is to advise you that the type "GF"
and type "GK" potential transformers, manufactured
by the Sangamo Company, Limited, Toronto, Canada,
have been approved by the National Research Council
of Canada in Canada on 60 cycle circuits only, in the
following ratios:

5:1; 10:1; 20:1; 50:1 and 60:1.

Yours truly,


Director.

JFB/m.c.