

N.R.C. 102
Electricity

DEPARTMENT OF TRADE AND COMMERCE
ELECTRICITY AND GAS INSPECTION SERVICES

OTTAWA, Sept. 14, 1937.

TO DISTRICT INSPECTORS OF
ELECTRICITY AND GAS

Re: Type Approval Sangamo type "LV"
Current Transformer on 60-cycle
Circuits.

Dear Sirs:

This is to advise you that the Sangamo type "LV" 60-cycle current transformer, manufactured by the Sangamo Company, Limited, Toronto, Canada, has been approved by the National Research Council for use in Canada in the following ratios, namely, from 5:5 amperes to 500:5 amperes, provided that the burden imposed on the transformer is such that the legal limits of error established by the Electricity Inspection Act will not be exceeded.

Yours truly,



Director.

JLS/mee