

N.R.C. 104
Electricity

DEPARTMENT OF TRADE AND COMMERCE
ELECTRICITY AND GAS INSPECTION SERVICES .

OTTAWA, October 28, 1937.

TO DISTRICT INSPECTORS OF
ELECTRICITY AND GAS

Re: Type Approval Canadian General
Electric Type I-30-A Watthour
Meter

Dear Sirs:

This is to advise you that the type I-30-A watthour meter, manufactured by the Canadian General Electric Company, Toronto, Ontario, has been approved by the National Research Council for use in Canada in the following capacities:

Amperes: 5, 10, 15, ^{25 - 16 & 10} 50, and transformer type
2½ ampere rating;

Voltages: 115, 230, 575;

Frequency: 60 cycles;

Circuits: 2 and 3 wire.

Yours truly,


Director.

JLS/mee