

DEPARTMENT OF TRADE AND COMMERCE
ELECTRICITY AND GAS INSPECTION SERVICES

OTTAWA, May 19, 1938.

TO DISTRICT INSPECTORS OF
ELECTRICITY AND GAS

Re: Type Approval Sangamo Demand
Meter Type "WDA".

Dear Sirs:

This is to advise you that the type "WDA" demand meter, manufactured by the Sangamo Company, Limited, Toronto, Ontario, has been approved for use in Canada by the National Research Council, in the following capacities:

Single-phase Meters

Amperes - 5/10/15/25/50
Voltage - 115/230
Frequency - 25 and 60 cycles
Circuits - 2 and 3 wire.

Polyphase

Amperes - 5
Voltage - 115/230/460/575
Frequency - 25 and 60 cycles.

Yours truly,


Director.

JLS/mee