

DEPARTMENT OF TRADE AND COMMERCE
ELECTRICITY AND GAS INSPECTION SERVICES

OTTAWA, September 13, 1938.

TO DISTRICT INSPECTORS OF
ELECTRICITY AND GAS

Re: Approval Ferranti type "FR"
60-cycle, single-phase Watthour
Meter.

Dear Sirs:

This is to advise you that the type "FR" single-phase watthour meter, manufactured by the Ferranti Limited, Hollinwood, Lancashire, England, and sold in Canada by the Ferranti Electric, Limited, Toronto, Ontario, is approved by the National Research Council for use in Canada in the following capacities:

Amperes: 5, 10, 15, 25 and 50;
Voltages: 115, 230 and 575;
Circuits: 2 and 3 wire;
Frequency: 60 cycle;
Dial: Clock or cyclometer;
Case: Standard or detachable.

The type "FR" 25-cycle watthour meter has been approved. (See Circular N.R.C. 112.)

Yours truly,


J. R. Stiver,
Director.

JLS/mee