

N.R.C. 115  
Electricity

DEPARTMENT OF TRADE AND COMMERCE  
ELECTRICITY AND GAS INSPECTION SERVICES

OTTAWA, November 24, 1938.

TO DISTRICT INSPECTORS OF  
ELECTRICITY AND GAS

Re: Approval of Canadian General Electric  
Type I-20A-TS Watthour Meter  
(Transformer type)

Dear Sirs:


I beg to advise you that the type I-20A-TS (transformer type) watthour meter, manufactured by the Canadian General Electric Company, Toronto, Canada, has been approved by the National Research Council for use in Canada in the following capacities, when equipped with the name-plate in accordance with the following:

Amperes: 2.5;  
Voltages: 115, 230, 460, 575;  
Wire: Single-phase 2 and 3 wire;  
Frequency: 25 and 60 cycle.

Type I-20A-TS Name Plate, C.G.E. Drawing #A-181985

Type I-20A-TS Single Phase Watthour Meter			
For use with inst. trans.	Secondary ratings	<input type="checkbox"/> A	<input type="checkbox"/> IV
C.Trans.Ratio	<input type="checkbox"/> to 1	P.Trans. Ratio	<input type="checkbox"/> to 1
No.	<input type="text"/>	Wire	<input type="text"/> $I_h$ <input type="text"/>
		Cycles	<input type="text"/>
Canadian General Electric Company Limited, Toronto, Can.			

Yours truly,

  
J. L. Stiver,  
Director.

JLS/mee