

DEPARTMENT OF TRADE AND COMMERCE  
ELECTRICITY AND GAS INSPECTION SERVICES

OTTAWA, January 9, 1939.

TO DISTRICT INSPECTORS OF  
ELECTRICITY AND GAS

Re: Approval of Canadian General  
Electric Type "V-3A" Polyphase  
Watt-hour Meters.

---


Dear Sirs:

This is to advise you that the type "V-3A" polyphase watt-hour meters, manufactured by the Canadian General Electric Company, Toronto, Canada, has been approved by the National Research Council for use in Canada in the following capacities:

Amperes: 2.5 transformer type,  
5/10/15/25/50;  
Voltage: 115/230/460/575;  
Frequency: 60 cycles;  
Circuit: 3-phase, 3-wire.

These meters are also approved when equipped with type "M-20" and type "M-21" demand registers, and type "D-13" contacts.

Yours truly,

  
J. L. Stiver,  
Director.

---

11/1/39