

DEPARTMENT OF TRADE AND COMMERCE
ELECTRICITY AND GAS INSPECTION SERVICES

OTTAWA, January 23, 1939.

TO DISTRICT INSPECTORS OF
ELECTRICITY AND GAS

Re: Approval of type "RW"
Demand Registers.

Dear Sirs:


This is to advise you that the type "RW" demand registers, manufactured by the Canadian Westinghouse Company, Limited, Hamilton, Ontario, has been approved by the National Research Council for use in Canada under the following conditions:

Provided the scale is divided into at least fifty divisions of equal value -

Interval: 10, 15, 30 and 60 minute;
Frequency: 60 cycle.

Types of meters on which it may be installed:
"C-2", "C-5", "CS-2" and "CS-5", "OC" and "CS".

Yours truly,


L. Stiver,
Director.

JLS/mee