

N.R.C. 119
Electricity

DEPARTMENT OF TRADE AND COMMERCE
ELECTRICITY AND GAS INSPECTION SERVICES

OTTAWA, January 31, 1939.

TO DISTRICT INSPECTORS OF
ELECTRICITY AND GAS

Re: Approval of Type "CFS"
Watt-hour Meter.


Dear Sirs:

This is to advise you that the type "CFS" single-phase detachable watt-hour meter, manufactured by the Sangamo Company, Limited, Toronto, Ontario, has been approved by the National Research Council for use in Canada in the following capacities:

Amperes: 5, 10, 15, 25, 50;
Voltages: 115, 230, 460, 575;
Frequency: 25 and 60 cycle;
Circuits: 2 and 3 wire;
Registers: Clock and cyclometer.

The type "CFS" meter is also approved when equipped with the Sangamo type "HG" demand attachment.

Yours truly,


J. L. Stiver,
Director.

*See NRC
#134*

JLS/mee