

N.R.C. 120
Electricity

DEPARTMENT OF TRADE AND COMMERCE

ELECTRICITY AND GAS INSPECTION SERVICES

TO DISTRICT INSPECTORS OF
ELECTRICITY AND GAS

APR 13 1931

Re: Approval of Type "ALS" Packard
Watthour Meter.

Dear Sirs:

This is to advise you that the Type "ALS" watthour meter, manufactured by the Packard Electric Company of St. Catharines, Ontario, has been approved by the National Research Council for use in Canada, in the following capacities:

Amperes: 5, 10, 15, 25 and 50;

Volts: 115, 230, 460 and 575;


Cycles: 25 and 60;

Register: Clock and cyclometer;

Circuits: Single-phase, 2 and 3 wire.

This meter is the type "A1" watthour meter with certain improvements and the socket-type base, usually indicated by the letter "S".

Yours truly


J. L. Stiver,
Director.

JLS/mee