

DEPARTMENT OF TRADE AND COMMERCE  
ELECTRICITY AND GAS INSPECTION SERVICES

OTTAWA, July 31, 1939.

TO DISTRICT INSPECTORS OF  
ELECTRICITY AND GAS

Re: Approval Sangamo Type "ED-30"  
Single-phase, Combination De-  
mand Energy Meter with Connect-  
ing Links.


---

Dear Sirs:

This is to advise you that the type "ED-30" single-phase combination demand energy meter with connecting links, manufactured by the Sangamo Company, Limited, Toronto, Canada, has been approved by the National Research Council for use in Canada in the following capacities:

Amperes: 15;  
Voltages: 115, 230;  
Frequency: 60-cycle;  
Circuits: 2 and 3 wire.

Yours truly,

  
J. L. Stiver,  
Director.

---

JLS/mee