

File No. 1023

N. R. C. 136

Electricity

DEPARTMENT OF TRADE AND COMMERCE
ELECTRICITY AND GAS INSPECTION SERVICES

OTTAWA, January 31, 1940.

TO DISTRICT INSPECTORS OF
ELECTRICITY AND GAS.

Re: Approval of Type "CM" Current
Transformers, Manufactured By
Bepco Canada Limited, Montreal,
P. Q.

Dear Sirs:

This is to advise you that the type "CM" current transformer, manufactured by Bepco Canada Limited, Montreal, P. Q., has been approved by the National Research Council for use in Canada in the following ratings and capacities:

Primary Ratings: 600, 300, 200, 150, 120,
100, 75, 60, 50, 40,
30, 25, 20, 15 and
10 amperes;

Secondary Ratings: 5 amperes;

Capacity: 15 volt-amperes;

Frequency: 60 cycle.

Yours truly,



J. L. Stiver,
Director.

JLS/mee