

Electricity

DEPARTMENT OF TRADE AND COMMERCE  
ELECTRICITY AND GAS INSPECTION SERVICES

OTTAWA, April 1, 1940.

TO DISTRICT INSPECTORS OF  
ELECTRICITY AND GAS.

Re: Approval of Types "FR", "FRA" and "FRS"  
Ferranti Watthour Meters


Dear Sirs:

This is to advise you that the types "FR", "FRA" and "FRS" watthour meters, manufactured by Ferranti Limited, Hollinwood, Lancashire, England, and sold in Canada by the Ferranti Electric, Limited, Toronto, Ontario, have been approved by the National Research Council for use in Canada in the following capacities:

Amperes:	5, 10, 15, 25, 50;
Voltages:	115, 230, 575;
Circuits:	<u>2</u> -phase, 2- and 3-wire;
Frequency:	25 and 60 cycle;
Dial:	Clock or cyclometer.

These meters are similar to the types that were approved by Circulars N.R.C. 112 and 113, except for changes made in the series coil to improve the balance feature.

Yours truly,



J. L. Stiver,  
Director.

JLS/mee