

Electricity

DEPARTMENT OF TRADE AND COMMERCE
ELECTRICITY AND GAS INSPECTION SERVICES

OTTAWA, April 1, 1940.

TO DISTRICT INSPECTORS OF
ELECTRICITY AND GAS.

Re: Approval of Types "L2A" and "L2S"
Two-element, Single disc, 25-cycle
Sangamo Watthour Meters

Dear Sirs:

This is to advise you that the types "L2A" and "L2S" two-element, single disc watthour meters, manufactured by the Sangamo Electric Company, Springfield, Illinois, U. S. A., and sold in Canada by the Sangamo Company, Limited, Toronto, Ontario, have been approved by the National Research Council for use in Canada in the following capacities:

Amperes: 5, 10, 15, 25, 50;
Voltages: 115, 230, 460, 575;
Frequency: 25 cycle;

The types "L2A" and "L2S" for 60-cycle circuits have been approved by Circulars N.R.C. 89 and 126.

Yours truly,



J. L. Stiver,
Director.

JLS/mee