

Electricity

DEPARTMENT OF TRADE AND COMMERCE
ELECTRICITY AND GAS INSPECTION SERVICES

OTTAWA, June 11, 1940.

TO DISTRICT INSPECTORS OF
ELECTRICITY AND GAS.

Re: Type Approval of Sangamo Type "LV"
Current Transformers on 25 and 60
Cycles

Dear Sirs:

This is to advise you that the type "LV" current transformers, manufactured by Sangamo Company, Limited, Toronto, Canada, has been approved by the National Research Council for use in Canada in the following capacities:

Primary currents up to 600 amperes;

Secondary current, 5 amperes;

Frequency, 25, 50 and 60 cycles;

Maximum burden, 7.5 volt-amperes.

Yours truly,



J. L. Stiver,
Director.

JLS/mee