

DEPARTMENT OF TRADE AND COMMERCE  
ELECTRICITY AND GAS INSPECTION SERVICES

OTTAWA, July 19, 1940.

TO DISTRICT INSPECTORS OF  
ELECTRICITY AND GAS

Re: Type Approval of Canadian General  
Electric Types "I-30A" and "I-30S"  
Single-phase Watthour Meters for  
25 Cycles


Dear Sirs:

This is to advise you that the types "I-30A"  
and "I-30S" single-phase watthour meters, manufactured  
by the Canadian General Electric Company, Toronto, Canada,  
have been approved by the National Research Council for  
use in Canada in the following capacities:

Amperes; 2.5 (transformer type),  
5, 10, 15, 25 and 50;  
Voltages: 115, 230 and 575;  
Frequency: 25 cycles;  
Circuits: 2- and 3-wire.

Approval is also given for the use of the  
"M-20" and "M-21" demand registers on these meters in any  
of the capacities already approved for 60-cycle meters.

Yours truly,



per H. A. Dupré,  
Assistant Director.

HAD/mee