

DEPARTMENT OF TRADE AND COMMERCE  
ELECTRICITY AND GAS INSPECTION SERVICES

OTTAWA, December 16, 1940.

TO DISTRICT INSPECTORS OF  
ELECTRICITY AND GAS

Re: Approval of Canadian General Electric  
Type "V-4A" Polyphase, Three-Element  
Wathour Meter

Dear Sirs:

This is to advise you that the type "V-4A" poly-  
phase, three-element wathour meter, manufactured by the  
Canadian General Electric Company, Toronto, Ontario, has  
been approved by the National Research Council for use in  
Canada in the following capacities:

Amperes: 2.5, 5, 10, 15, 25, 50;

Voltages: 115, 230, 460, 575;

Frequency: 60 cycles.

Approval is also given for the use of the types  
"M-20" and "M-21" demand attachments, and contact devices  
"D-5", "D-12" and "D-13" with this meter.

Yours truly,



J. L. Stiver,  
Director.

JLS/mee