

File No. 796

N.P.C. 164
Electricity

DEPARTMENT OF TRADE & COMMERCE
ELECTRICITY AND GAS INSPECTION SERVICES

OTTAWA, 17 April 1946

TO DISTRICT INSPECTORS OF
ELECTRICITY AND GAS

Re: Types CA-2 and CA-5 Polyphase
Watt-hour Meters
Canadian Westinghouse Limited, Hamilton, Ont.

Dear Sirs:

This is to advise you that the types CA-2 and CA-5 Polyphase Watt-hour meters manufactured by the Canadian Westinghouse Limited, Hamilton, Ontario, have been approved by the National Research Council for use in Canada in the following capacities:

Voltage ratings: 115, 230, 460 and 575 volts.

Alternate markings: 120, 240, 480 and 600
or: 115-120, 230-240, 460-480 and 575-600.


Current ratings:

Rated current	Maximum current
2.5	7.5
5	15
10	30
15	45
25	75
50	100

Frequency 60 cycles.

This approval covers the use of approved metering, accessories such as: demand register, cyclometer dial, potential indicating lamps. It also covers variations in the terminal arrangement to suit the normal uses of two element meters.

Yours truly,


J. L. Stiver,
Director.