



SD-EA.10

CANADA

DEPARTMENT OF TRADE AND COMMERCE
STANDARDS DIVISION

OTTAWA, May 16, 1950.
(Superseding Circular Letter SD-EC.34,
dated October 14, 1948)


NOTIFICATION OF TYPE APPROVAL

The apparatus specified herein has been duly approved by the Standards Division under the provisions of The Electricity Inspection Act, Chapter 22, 1928, and may be admitted to verification in Canada.

Apparatus Approved: New Lag-Plate Assembly, manufactured by the Canadian General Electric Company, Toronto, Canada, for use on types "L-30A" and "L-30S" Canadian General Electric watt-hour meters.

Rating of Apparatus: All approved ratings of the above-named types of meters.

Description: The new lag-plate assembly is provided with temperature compensation for inductive load, and is so made that it can be removed and replaced without changing the light load or lag adjustment of the meter. There is no material change from the lag-plate used on the meter originally approved.


R. W. MacLean,
Director,
Standards Division.


E. F. Power,
Assistant Director (E. & G.),
Standards Division.