



SD-EA.14

CANADA

DEPARTMENT OF TRADE AND COMMERCE  
STANDARDS DIVISION

OTTAWA, May 20, 1950.  
(Superseding Circular Letter SD-EC.56,  
dated September 15, 1949)

NOTIFICATION OF TYPE APPROVAL

The apparatus specified and illustrated herein has been duly approved by the Standards Division under the provisions of The Electricity Inspection Act, Chapter 22, 1928, and may be admitted to verification in Canada.

Apparatus Approved: Type "A" Auxiliary Current Transformer, manufactured by the Packard Electric Company, Limited, St. Catharines, Ontario.

Rating of Apparatus:

Ratios ..... 5:5, 10:5, 15:5 and 20:5  
Frequency .... 60 cycles

Description: This type was designed for use as an auxiliary current transformer to totalize the secondary currents of two or more regular current transformers.

*E. F. Power*

E. F. Power,  
Assistant Director (E. & G.),  
Standards Division.

*R. W. Maclean*  
R. W. Maclean,  
Director,  
Standards Division.

