



CANADA

DEPARTMENT OF TRADE AND COMMERCE
STANDARDS DIVISIONOTTAWA, May 23, 1950.
(Superseding Circular Letter SD-EC.64,
dated January 7, 1950)

NOTIFICATION OF TYPE APPROVAL

The apparatus specified and illustrated herein has been duly approved by the Standards Division under the provisions of The Electricity Inspection Act, Chapter 22, 1928, and may be admitted to verification in Canada.

Apparatus Approved: New Type Clock Register, for use on types "CA" and "CS" single-phase watt-hour meters, manufactured by the Canadian Westinghouse Company, Limited, Hamilton, Ontario.

Rating of Apparatus: All approved ratings of the above-named types of meters.

Description: The main gear case and the face plate of this register are larger than those of the old register. This separates the dials, which no longer intersect, and makes readings much more legible. The method of mounting and the gear arrangement are the same as before.

E. F. Power

E. F. Power,
Assistant Director (E. & G.),
Standards Division.

R. W. MacLean,
Director,
Standards Division.

