



CANADA

DEPARTMENT OF TRADE AND COMMERCE
STANDARDS DIVISION

OTTAWA, August 15, 1950.

NOTIFICATION OF TYPE APPROVAL

The apparatus specified herein has been duly approved by the Standards Division under the provisions of The Electricity Inspection Act, Chapter 22, 1928, as amended.

Apparatus Approved: The following instrument transformers, manufactured by the Packard Electric Company Limited, St. Catharines, Ontario:-

- (1) Type "HS", outdoor, O.I.S.C. (oil-insulated, self-cooled), single-phase, single bushing, double secondary potential transformer;
- (2) Type "F", outdoor, O.I.S.C., single-phase, single 2-conductor bushing current transformer.

Rating of Apparatus:

- (1) 500 VA., 60 cycles, 66500-115000Y/66.5-66.5 volts;
- (2) 50 VA., 60 cycles, 115000 volts, 400/5 amperes.

Limiting Conditions: These instrument transformers are designed for use on high potential metering. It has been agreed that this equipment is of a type and rating such that testing facilities are not readily available; hence, approval is granted based upon presentation of satisfactory evidence establishing that they are capable of performing in accordance with our requirements.

W. J. S. Fraser
for
E. F. Power,
Assistant Director (E. & G.),
Standards Division.

R. W. Maclean
R. W. Maclean,
Director,
Standards Division.