



CANADA

DEPARTMENT OF TRADE AND COMMERCE  
STANDARDS DIVISION

OTTAWA, March 7, 1951.

(Apparatus approved  
July 25, 1949)

## NOTIFICATION OF TYPE APPROVAL

The apparatus specified and illustrated herein has been duly approved by the Standards Division under the provisions of The Electricity Inspection Act, Chapter 22, 1928, and may be admitted to verification in Canada.

Apparatus Approved: Type "AR" single-phase Watthour Meter, manufactured by Smith Meters Limited, London, England.

## Rating of Apparatus:

Amperes ..... 10  
Volts ..... 110/220  
Frequency ..... 60 cycles  
Wire ..... 2 or 3  
Phase ..... 1

Description: This meter is of the ordinary bottom connected style (not A-base) with standard terminal connections. The base, cover, terminal cover, and sealing nuts are of moulded bakelite. The diagram of connections is moulded inside the terminal cover plate.

Conditions: Approval covers meters fitted with cyclometer registers but not those fitted with clock-type registers.

E. F. Power,  
Assistant Director, (E&G),  
Standards Division.

R. W. MacLean,  
Director,  
Standards Division.



Small, faint vertical text or markings along the left edge of the page, possibly bleed-through from the reverse side.

