



CANADA

DEPARTMENT OF TRADE AND COMMERCE  
STANDARDS DIVISION

OTTAWA, April 18, 1951.

## NOTIFICATION OF TYPE APPROVAL

The apparatus specified herein has been duly approved by the Standards Division under the provisions of The Electricity Inspection Act, Chapter 22, 1928, as amended, and may be admitted to verification in Canada.


Apparatus Approved: Type "AR" Single-Phase, and Type "P" Polyphase, Watthour Meters, manufactured by Smith Meters Limited, London, England.

## Rating of Apparatus:

	Type "AR"	Type "P"
Amperes .....	2 $\frac{1}{2}$ , 5, 25, 50	2 $\frac{1}{2}$ , 5, 25, 50
Volts .....	110/220	110 and 220
Frequency .....	60 cycles	60 cycles
Wire .....	2 or 3	3
Phase .....	1	2 or 3

Description: The type "AR" and the type "P" watthour meters were originally approved on July 25, 1949 (see Approval Circulars SD-EA.54 and SD-EA.55 of March 7, 1951), in a 10-ampere rating only. This Approval covers the 2 $\frac{1}{2}$ -, 5-, 25-, and 50-ampere ratings for the same types of meters. In addition, the type "P" is also approved for a 110-volt rating.

Conditions: Approval covers meters fitted with cyclometer registers, but not those fitted with clock-type registers.

  
R. W. Maclean,  
Director,  
Standards Division.



E. F. Power,  
Assistant Director, (E&G),  
Standards Division.