



CANADA

DEPARTMENT OF TRADE AND COMMERCE  
STANDARDS DIVISION

SD-EA.60

OTTAWA, April 19, 1951.

NOTIFICATION OF TYPE APPROVAL

The apparatus specified herein has been duly approved by the Standards Division under the provisions of The Electricity Inspection Act, Chapter 22, 1928, as amended, and may be admitted to verification in Canada.

Apparatus Approved: Types "CA-2", "CS-2", and "CB-2" Polyphase Watthour Meters for 50-cycle service, manufactured by the Canadian Westinghouse Company Limited, Hamilton, Ontario.

Rating of Apparatus: All ratings covered by the previous approvals for the 60-cycle equivalents.

See the following Approval Circulars:

Type "CA-2" - N.R.C.164, dated April 17, 1946

Type "CS-2" - N.R.C. 98, dated June 25, 1937

Type "CB-2" - SD-EA. 37, dated September 18, 1950.

Description: The essential elements of all three types are the same. The 50-cycle design is identical with the 60-cycle equivalent except for the potential coil circuit.

*E. F. Power*

E. F. Power,  
Assistant Director, (E&G),  
Standards Division.

*H. W. MacLean*  
H. W. MacLean,  
Director,  
Standards Division.

Ref: A-170a