

TRADE AND COMMERCE
CANADA

STANDARDS DIVISION

OTTAWA, August 21, 1952.

MODIFICATION OF TYPE APPROVALWESTINGHOUSE TYPES "CA" and "CS" WATTHOUR METERS

The modification to the apparatus specified herein has been duly approved by the Standards Division under the provisions of The Electricity Inspection Act, Chapter 22, 1928, as amended, and the modified apparatus may be admitted to verification in Canada.

Apparatus Modified: Clock-type Register for use on types "CA" and "CS" single-phase watthour meters, manufactured by the Canadian Westinghouse Company Limited, Hamilton, Ontario, approved in SD-EA.19, dated May 23, 1950 (original approval given in Circular Letter SD-EC.64, dated January 7, 1950)

Modification: The original approval covers the use of this register with the "CA" and "CS" single-phase meters only. This approval extends the use of the register to include all types "CA" and "CS" polyphase meters which have previously been approved.

E. F. Power,
Assistant Director (E&G),
Standards Division.

R. W. MacLean,
Director,
Standards Division.