

TRADE AND COMMERCE
CANADA

STANDARDS DIVISION

OTTAWA, August 18, 1953.

MODIFICATION OF TYPE APPROVALPACKARD TYPES "B1A" AND "B1S" SINGLE-PHASE WATTHOUR METERS

The modification to the apparatus specified herein has been duly approved by the Standards Division under the provisions of The Electricity Inspection Act, Chapter 22, 1928, as amended, and the modified apparatus may be admitted to verification in Canada.

Apparatus Modified: Types "B1A" and "B1S" Single-Phase Watthour Meters in the 25-ampere rated capacity, manufactured by the Packard Electric Company Limited, St. Catharines, Ontario.

Rating of Apparatus: The modification is approved for all presently approved 25-ampere meters of the "B1A" and "B1S" types, 2- or 3-wire, and in addition the combination 25-ampere, 2-wire/3-wire meter of these types.

Description: The modification consists of re-rating the "maximum amperes" of these meters in all cases to 100 amperes so that they may be used with any approved type of Packard register, whether standard, 5-dial, or with dial multiplier.

E. F. Power

E. F. Power,
Assistant Director (E&G),
Standards Division.

R. W. MacLean
R. W. MacLean,
Director,
Standards Division.