

TRADE AND COMMERCE
CANADA

SD-EA.116

STANDARDS DIVISION

OTTAWA, August 21, 1953.

MODIFICATION OF TYPE APPROVALPACKARD TYPES "B1A" AND "B1S" SINGLE-PHASE WATTHOUR METERS

The modification to the apparatus specified and illustrated herein has been duly approved by the Standards Division under the provisions of The Electricity Inspection Act, Chapter 22, 1928, as amended, and the modified apparatus may be admitted to verification in Canada.

Apparatus Modified: Types "B1A" and "B1S" Single-Phase Watthour Meters, manufactured by the Packard Electric Company Limited, St. Catharines, Ontario.

Rating of Apparatus: All previously approved ratings and variations of these meters.

Modification: The modification consists of a new pivot-type lower bearing. This may be used in place of the regular jewel holder and ball in conjunction with the standard Packard lower bearing holder. The new pivot is interchangeable with the regular jewel holder.

E. F. Power

E. F. Power,
Assistant Director (E&G),
Standards Division.

R. W. MacLean
R. W. MacLean,
Director,
Standards Division.

Ref: A-273D

NEW PIVOT-TYPE LOWER BEARING
FOR PACKARD "B1A" AND "B1S" WATTHOUR METERS

