

TRADE AND COMMERCE
CANADA

SD-EA.120

STANDARDS DIVISION

OTTAWA, September 21, 1953.

TYPE APPROVALCANADIAN GENERAL ELECTRIC
TYPE "KF78B" CURRENT TRANSFORMER

The apparatus specified and illustrated herein has been duly approved by the Standards Division under the provisions of The Electricity Inspection Act, Chapter 22, 1928, as amended, and may be admitted to verification in Canada.


Apparatus Approved: Type "KF78B" Current Transformer, manufactured by the Canadian General Electric Company Limited, Toronto, Ontario.

Rating of Apparatus:

Primary Current	5, 10, 12.5, 15, 20, 25, 30, 40, 50, 60, 80, 100, 125, 150, 200, 250, 300, 400 amperes
Secondary Current	5 amperes
Primary Voltage Rating	8.7 KV
Accuracy Classification ...	0.3B0.1, 0.3B0.5 [*] , 0.6B2.0 - all 60-cycle ratings 0.6B0.1, 0.6B0.5, 0.6B2.0 - 40, 80, 400 amp., 25-cycle ratings 0.3B0.1, 0.3B0.5, 0.3B2.0 - all other 25-cycle ratings
Frequency	25/125 cycles
Style	Dry Outdoor

* shown on nameplate.

Description: The type "KF78B" current transformers are the dry outdoor type. They are enclosed in a case which is identical to that of the type KF81B, and other details of construction, polarity marking, leads, etc., are similar.


R. W. MacLean,
Director,
Standards Division.



E. F. Power,
Assistant Director (E&G),
Standards Division.

Ref: A-296

CANADIAN GENERAL ELECTRIC
TYPE "KF78B" CURRENT TRANSFORMER

