

TRADE AND COMMERCE
CANADA

SD-EA.132

STANDARDS DIVISION

OTTAWA, December 3, 1953.

TYPE APPROVALCANADIAN GENERAL ELECTRIC TYPE "JKP-O" CURRENT TRANSFORMER

The apparatus specified herein has been duly approved by the Standards Division under the provisions of The Electricity Inspection Act, Chapter 22, 1928, as amended, and may be admitted to verification in Canada.


Apparatus Approved: Type "JKP-O" Current Transformer, manufactured by the Canadian General Electric Company Limited, Toronto, Ontario.


Rating of Apparatus:

Ratios	2-wire with one turn of primary conductor - 800/5 amperes
	2-wire with two turns of primary conductor - 400/5 amperes
	3-wire with one turn of each primary conductor - 400 - 400/5 amperes
	3-wire with two turns of each primary conductor - 200 - 200/5 amperes
Rated Metering Burden	12.5 VA at 0.9 p.f.
A.S.A. Accuracy Rating [*]	0.3B0.1, 0.3B0.2
Rated Voltage	600 volts with bare conductor; higher voltages depending on insulation of conductor
Wire	2 or 3
Phase	1
Frequency	25 - 60 cycles
Style	Dry Indoor or Outdoor

^{*} Not marked on nameplate.

Description: Except for the ratio, these transformers are similar in appearance and other details to the type "JKP-O" current transformers approved under Circular SD-EA.95 of February 18, 1953.


R. W. MacLean,
Director,
Standards Division.


E. F. Power,
Assistant Director (E&G),
Standards Division.

Ref: A-291A