



TRADE AND COMMERCE  
CANADA

## STANDARDS DIVISION

OTTAWA.....January 5, 1954.

TYPE APPROVALPACKARD TYPE "LM" CURRENT TRANSFORMER

The apparatus specified herein has been duly approved by the Standards Division under the provisions of The Electricity Inspection Act, Chapter 22, 1928, as amended, and may be admitted to verification in Canada.

Apparatus Approved: Type "LM" Current Transformer, manufactured by the Packard Electric Company Limited, St. Catharines, Ontario.

## Rating of Apparatus:

Primary Current ..... 600 and 800 amperes  
 Secondary Current ..... 5 amperes  
 Accuracy Rating ..... ASA 0.6B0.2  
 Rated Voltage ..... 600 volts  
 Wire ..... 2  
 Frequency ..... 60 cycles  
 Style ..... Dry Indoor.

Description: These transformers are to the same design as those approved on Circular SD-EA.127, October 26, 1953; the range of ratios of the type is thus extended to include the 600/5 and 800/5 ratios.

E. F. Power,  
Assistant Director (E&G),  
Standards Division.

R. W. MacLean,  
Director,  
Standards Division.

Ref: A-331B