



TRADE AND COMMERCE
CANADA

SD-EA.168

STANDARDS DIVISION

OTTAWA..... November 25, 1954.

TYPE APPROVALENGLISH ELECTRIC TYPES "B-21A" AND "B-21S" WATTHOUR METERS

The apparatus specified herein has been duly approved by the Standards Division under the provisions of the Electricity Inspection Act, Chapter 94, R.S. 1952, and may be admitted to verification in Canada.

Apparatus Approved: Types "B-21A" and "B-21S" Single-Phase Watthour Meters, manufactured by the English Electric Company of Canada Limited, St. Catharines, Ontario.

Rating of Apparatus:

Nominal Amperes	5	10	15	25
Maximum Amperes	20	40	60	100
Volts	115	115 & 230	115 & 230	115 & 230
	<u>OR</u> 120	120 & 240	120 & 240	120 & 240
Frequency	50 or 60	50 or 60	50 or 60	50 or 60
Wire	2	2 or 3	2 or 3	2 or 3
Phase	1	1	1	1

Description: These meters are identical to those approved by Circular SD-EA.65 of August 20, 1951, except that, if desired by the manufacturer, the nameplates may be marked with either 115, 230 volt ratings or 120,240 volt ratings instead of the 110, 220 volt ratings already approved.

E. F. Power,
Assistant Director (E&G),
Standards Division.

R. W. MacLean,
Director,
Standards Division.

Ref: A-228C