

TRADE AND COMMERCE
CANADA

STANDARDS DIVISION

OTTAWA, December 21, 1954.

TYPE APPROVALPACKARD TYPES "B-X", "BF-X" AND "BF-X SPECIAL"
VOLTAGE TRANSFORMERS

The apparatus specified herein has been duly approved by the Standards Division under the provisions of the Electricity Inspection Act, Chapter 94, R.S. 1952, and may be admitted to verification in Canada.

Apparatus Approved: Types "B-X", "BF-X" and "BF-X Special" Single Secondary Voltage Transformers, manufactured by the Packard Electric Company Limited, St. Catharines, Ontario.

Rating of Apparatus:

Rated Voltage 2200-110, or 2300-115, or 2400-120
 Volt-Amperes 200
 Accuracy Rating* ASA 0.3WXY, 0.6Z
 Thermal Rating 1200 VA @ 55°C. rise
 Insulation Class 2.5 KV
 Frequency 60 cycles
 Style Dry Indoor

* Shown on the nameplate.

Description: The appearance and general design are essentially the same as the types "B-X", "BF-X" and "BF-X Special" described under Circular SD-EA.160 of October 22, 1954, except for the single secondary in this case.

E. F. Power,
 Assistant Director (E&G),
 Standards Division.

R. W. MacLean,
 Director,
 Standards Division.

Ref: A-401-A