

SD-EC.

S. D. E. C. 170

DEPARTMENT OF TRADE & COMMERCE
STANDARDS DIVISION

File No. S.837

OTTAWA, Ont., 14th August 1947

TO DISTRICT INSPECTORS
OF ELECTRICITY & GAS


Re: Approval Alnico Magnets for
Canadian General Electric
Wattour Meters

Dear Sirs:

This is to advise you that the new design of the Alnico Permanent Magnets manufactured by the Canadian General Electric Company, Toronto, Canada, has been approved by the National Research Council for use in all approved types of wattour meters manufactured by the Canadian General Electric Company.

This new type of magnet will be used in type I-30 wattour meter production and will be supplied as a renewal part where necessary for all older types of meters, including the I-20, I-16 and I-14.

Yours truly,



J. L. Stiver,
Assistant Director of Standards.

JLS:bk