

DEPARTMENT OF



TRADE AND COMMERCE
CANADA

SD-EA.174

STANDARDS DIVISION

OTTAWA.....January 19, 1955.

TYPE APPROVAL

CANADIAN GENERAL ELECTRIC TYPE "V-"
POLYPHASE WATTHOUR METERS

The apparatus specified herein has been duly approved by the Standards Division under the provisions of the Electricity Inspection Act, Chapter 94, R.S. 1952, and may be admitted to verification in Canada.

Apparatus Approved: Types "V-2A", "V-3A", "V-4A", "V-5A", "V-6A" and "V-2S", "V-3S", "V-5S", "V-6S" Polyphase Watthour Meters, manufactured by the Canadian General Electric Company Limited, Toronto, Ontario.

Rating of Apparatus: As previously approved except for the voltage rating.

Description: These meters are identical to the "V-" types approved under previous approval circulars except that the manufacturer is permitted to mark the nameplates with 120-volt ratings or multiples thereof instead of the former 115 volts and multiples.

E. F. Power

E. F. Power,
Assistant Director (E&G),
Standards Division.

R. W. MacLean

R. W. MacLean,
Director,
Standards Division.

Ref: A-412A