

TRADE AND COMMERCE
CANADA

STANDARDS DIVISION

OTTAWA, February 4, 1955.

TYPE APPROVALPACKARD TYPES "E-5" AND "E-15" CURRENT TRANSFORMERS

The apparatus specified herein has been duly approved by the Standards Division under the provisions of the Electricity Inspection Act, Chapter 94, R.S. 1952, and may be admitted to verification in Canada.

Apparatus Approved: Types "E-5" and "E-15" Current Transformers, manufactured by the Packard Electric Company Limited, St. Catharines, Ontario.

Rating of Apparatus:

Primary Current	500 amperes
Secondary Current	5 amperes
Voltage Rating	5 KV and 15 KV
Accuracy Rating	0.3B0.1, 0.3B0.5*, 0.3B2.0 on 60 cycles 0.3B0.1, 0.3B0.5, 0.6B2.0 on 25 cycles
Frequency	25-60 cycles
Style	Dry Indoor

* marked on nameplate.

Description: Except for small differences in cross-sectional area of the magnetic core and in the ampere-turns, those transformers are the same as those approved under Circular SD-EA.106, May 13, 1953.

E. F. Power,
Assistant Director (E&G),
Standards Division.

R. W. MacLean,
Director,
Standards Division.

Ref: A-294C & A-294D

