



TRADE AND COMMERCE
CANADA

SD-EA.177

STANDARDS DIVISION

OTTAWA, February 10, 1955.

TYPE APPROVAL

SANGAMO TYPES "NBS" AND "NBAP"
POLYPHASE WATTHOUR METERS

The apparatus specified herein has been duly approved by the Standards Division under the provisions of the Electricity Inspection Act, Chapter 94, R.S. 1952, and may be admitted to verification in Canada.

Apparatus Approved: Types "NBS" and "NBAP" Polyphase Watthour Meters, manufactured by the Sangamo Company Limited, Leaside, Toronto 17, Ontario.

Rating of Apparatus:

Nominal Amperes 2.5, 5, 10, 15, 25, 50
 Maximum Amperes 10, 20, 40, 60, 75, 100
 Voltages 120, 240, 480, 600
 Wire 3
 Elements 2
 Frequency 60 cycles.

Description: These meters are identical to the same types approved on Circulars SD-EA.133 and SD-EA.147 except that the manufacturer is permitted to mark the nameplates with 120-volt ratings or multiples thereof instead of the former 115 volts and multiples thereof.

E. F. Power,
Assistant Director (E&G),
Standards Division.

R. W. MacLeary
Director,
Standards Division.

Ref: A-424

