

TRADE AND COMMERCE
CANADA

SD-EA.160

STANDARDS DIVISION

OTTAWA, March 15, 1955.

TYPE APPROVALHYDRO-ELECTRIC POWER COMMISSION
TYPES "H-8.7" AND "H-15" VOLTAGE TRANSFORMERS

The apparatus specified herein has been duly approved by the Standards Division under the provisions of the Electricity Inspection Act, Chapter 94, R.S. 1952, and may be admitted to verification in Canada.

Apparatus Approved: Types "H-8.7" and "H-15" Voltage Transformers, manufactured or modified expressly to Specifications of the Hydro-Electric Power Commission of Ontario, 620 University Avenue, Toronto 2, Ontario.

Rating of Apparatus:	Type "H-8.7"	Type "H-15"
Primary Voltage Rating	4800/2400	7200
Secondary Voltage Rating	120	120
Insulation Class	8.7 KV	15 KV
Accuracy Rating	ASA 0.3Y, 0.6Z	ASA 0.3Y, 0.6Z
Frequency	25 cycles	25 cycles

Description: Except for the different frequency, these transformers are similar to the same types approved previously. The descriptions and limitations of Approval Circulars SD-EA.153 of June 15, 1954 and SD-EA.154 of July 19, 1954 apply.

Note: Those Inspection Districts situated outside the Province of Ontario need not be concerned with this approval notice.

E. F. Power,
Assistant Director (E&G),
Standards Division.

R. W. MacLean,
Director,
Standards Division.

Ref: A-382B

